

# TEST CERTIFICATE

CT-12-08-02-02

**Product:** Homapal - High Pressure Laminate with Melamine surface

**Company:** Homapal Plattenwerk GmbH & Co. KG  
Bahnhofstraße 30/32, D-37412 Herzberg

**Order:** Determination of the formaldehyde release of Homapal - High Pressure Laminate with Melamine surface according to the test chamber method DIN EN 717-1

**Test method:** Test chamber method DIN EN 717-1  
Chemical analysis formaldehyde: Acetyl acetone method


**Test report:** Test report 252253 dated August 02<sup>nd</sup>, 2012

**Test result:** The formaldehyde release of Homapal - High Pressure Laminate with Melamine surface is 0.02 ppm (240 h).  
The Homapal - High Pressure Laminate with Melamine surface fulfils surely the limiting value of 0.1 ppm of ChemVerbotsV § 1 (3) regarding formaldehyde.

Dresden, August 02<sup>nd</sup>, 2012

A handwritten signature in blue ink, appearing to read 'i.v. Dr. B...', is written over a horizontal line.

Head of laboratory

A handwritten signature in black ink, appearing to read 'Hofenichler', is written over a horizontal line.

Engineer in charge